

- I. ONE VERTICAL LOOP VENT SHALL BE PROVIDED AT THE END OF URINALS & EVERY THREE URINALS.
- 2. AIR ADMITTANCE VALVE (AAV) MAY BE USED IN LIEU OF VENTILATING PIPE AND LOOP VENTING PIPE.
- 3. AAV SHALL COMPLY WITH EN 12380 & SHALL BE INSTALLED ABOVE THE SPILL-OVER LEVEL OF THE APPLIANCE SERVED.

ALL DIMENSIONS ARE IN mm.

| ISSUED : DEC 2021 | SCALES | NOT 10 | TO 10 | SCALE | NOT 2021 | NOT 20

VENTILATING PIPE REQUIREMENTS FOR URINALS CONNECTED IN SERIES

